


PHPP-Energy balance calculation



Architecture: Plan B d.o.o.
 Street: Gregorčičeva 21/b
 Postcode/City: 2000 Maribor
 Province/Country: Slovenija SI-Slovenia

Energy consultancy: REING d.o.o.
 Street: Borovnjakova 12
 Postcode/City: 9000 Murska Sobota
 Province/Country: Slovenija SI-Slovenia

Year of construction: 2018
 No. of dwelling units: 1
 No. of occupants: 150,0

Building: Šolski center Slovenj Gradec - telovadnica
 Street: k.o. Slovenj Gradec, Gosposvetska cesta
 Postcode/City: 3230 Šentjur
 Province/Country: Slovenija SI-Slovenia
 Building type: Športna dvorana
 Climate data set: ud--01-Ljubljana T1996-2005/J1981-2000
 Climate zone: 3: Cool-temperate Altitude of location: 309 m

Home owner / Client: Ministrstvo za izobraževanje, znanos in šport
 Street: Masarykova cest 16
 Postcode/City: 1000 Ljubljana
 Province/Country: Slovenija SI-Slovenia

Mechanical engineer: Klimada maks d.o.o.
 Street: Partizanska cesta 3
 Postcode/City: 2000 Maribor
 Province/Country: Slovenija SI-Slovenia

Certification:
 Street:
 Postcode/City:
 Province/Country: 2-User determined

Interior temperature winter [°C]: 20,0 Interior temp. summer [°C]: 25,0
 Internal heat gains (IHG) heating case [W/m²]: 2,1 IHG cooling case [W/m²]: 2,1
 Specific capacity [Wh/K per m² TFA]: 204 Mechanical cooling: x

Specific building characteristics with reference to the treated floor area

		Treated floor area m²		Criteria	Alternative criteria	Fullfilled? ²
Space heating	Heating demand kWh/(m²a)	2043,1		-	-	-
	Heating demand kWh/(m²a)	24,5	≤	-	-	-
	Heating load W/m²	3,87	≤	-	-	-
Space cooling	Cooling & dehum. demand kWh/(m²a)	15,3	≤	-	-	-
	Cooling load W/m²	3,7	≤	-	-	-
	Frequency of overheating (> 25 °C) %	5,7	≤	-	-	-
	Frequency of excessively high humidity (> 12 g/kg) %	-	≤	-	-	-
Airtightness	Pressurization test result n ₅₀ 1/h	0,0	≤	-	-	-
	PER demand kWh/(m²a)	0,6	≤	-	-	-
Non-renewable Primary Energy (PE)	PER demand kWh/(m²a)	40	≤	-	-	-
	Generation of renewable energy (in relation to projected building footprint area)	57	≥	-	-	-
Primary Energy Renewable (PER)		0,0	≥	-	-	-

² Empty field: Data missing; '-': No requirement

I confirm that the values given herein have been determined following the PHPP methodology and based on the characteristic values of the building. The PHPP calculations are attached to this verification.

Task: _____ First name: Matej Surname: Kramar
 Issued on: 12.04.18 City: Murska Sobota

Signature: _____

POPRAVLJENE LASTNOSTI PROFILOV IN STEKEL GLEDE NA DOKAZILA; POPRAVLJENE LASTNOSTI KLIMATA

U-value of building assemblies

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PE

Secondary calculation: Equivalent thermal conductivity of still air spaces -> (on the right)

Wedge-shaped assembly layer -> (on the right)

Unheated / uncooled attic -> (on the right)

Assembly no.	Building assembly description				Interior insulation?
01ud	P2 Športna dvorana, igrišče				
Heat transmission resistance [m ² K/W]					
Orientation of building element	3-Floor	interior R _{si}	0,17		
Adjacent to	2-Ground	exterior R _{se}	0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
plavajoči leseni pod	0,200				
sloj zraka	0,340	(s talnim ogrevanjem)			
PE folija	0,190				
kamena volna 035	0,035	(npr. KI DP-5)		lesena konstrukcija	0,130
hidroizolacija	0,190				
AB talna plošča	2,200				
XPS 035	0,035	(npr. Fibran xps 300L)			
gramozni tampon	1,600				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
90%				10,0%	
U-value supplement					U-value: 0,150 W/(m ² K)
					Total 76,9 cm

Assembly no.	Building assembly description				Interior insulation?
02ud	P2a Športna dvorana, ostale površine				
Heat transmission resistance [m ² K/W]					
Orientation of building element	3-Floor	interior R _{si}	0,17		
Adjacent to	2-Ground	exterior R _{se}	0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
epoksi tlak	0,700				
mikroarmirani beton	2,200	(s talnim ogrevanjem)			
PE folija	0,190				
EPS 036	0,036	(npr. FRAGMAT EPS 100)			
hidroizolacija	0,190				
AB talna plošča	2,200				
XPS 035	0,035	(npr. Fibran xps 300L)			
gramozni tampon	1,600				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%					
U-value supplement					U-value: 0,138 W/(m ² K)
					Total 77,0 cm

Assembly no.	Building assembly description				Interior insulation?
03ud	P3 Garderobe, sanitarije, komunikacije, lakirnica				
Heat transmission resistance [m ² K/W]					
Orientation of building element	3-Floor	interior R _{si}	0,17		
Adjacent to	2-Ground	exterior R _{se}	0,00		
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]
mikroarmirani beton	2,200	(s talnim ogrevanjem)			
PE folija	0,190				
EPS 036	0,036	(npr. Fragn. EPS 100)			
hidroizolacija	0,190				
AB talna plošča	2,200				
XPS 035	0,035	(npr. Fibran xps 300L)			
gramozni tampon	1,600				
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3	
100%					
U-value supplement					U-value: 0,149 W/(m ² K)
					Total 77,0 cm

Assembly no.		04ud				P4 Strojne delavnice, skladišče, ročna delavnica, kabinet (IZVEN FAZE 1)		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		3-Floor		interior R _{si}		0,17			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
mikroarmirani beton	2,200	(s talnim ogrevanjem)				95			
PE folija	0,190					0			
EPS 036	0,036					100			
hidroizolacija	0,190					5			
AB talna plošča	2,200					150			
XPS 035	0,035					120			
gramozni tampon	1,600					300			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						77,0		cm	
U-value supplement				U-value:		0,149		W/(m ² K)	

Assembly no.		05ud				N5 Tla povezovalnega hodnika		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		3-Floor		interior R _{si}		0,17			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
mikroarmirani beton	2,200	(s talnim ogrevanjem)				68			
PE folija	0,190					0			
EPS 036	0,036	(npr. Fragm. EPS100)				30			
AB talna plošča	2,200					200			
XPS 035	0,035	(npr. Fibran xps 300L)				200			
hidroizolacija	0,190					5			
podložni beton	2,200					100			
gramozni tampon	1,600					300			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						90,3		cm	
U-value supplement				U-value:		0,141		W/(m ² K)	

Assembly no.		06ud				S1 Ravna streha nad telovadnico		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		1-Roof		interior R _{si}		0,10			
Adjacent to		1-Outdoor air		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
mavčno-kartonske plošče	0,210					13			
zračni prostor	0,370					60			
folija	0,190					0			
OSB plošča	0,130					18			
kamena volna 035	0,035	(npr. KI DP-8)		morali 10/22	0,130	220			
OSB plošča	0,130					22			
kamena volna 039	0,039	(npr. KI DDP)				120			
strešna HI folija	0,190					10			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
84%				16,0%		46,3		cm	
U-value supplement				U-value:		0,117		W/(m ² K)	

Assembly no.		07ud				S2 Streha strojne delavnice (NI DEL FAZE 1)		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		1-Roof		interior R _{si}		0,10			
Adjacent to		1-Outdoor air		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB plošča	2,200					220			
naklonski beton	1,600	(od 2 do 17cm)				95			
bitumen	0,190					5			
EPS 031	0,031					240			
hidroizolacija	0,190					10			
folija	0,190					1			
prodec	1,600					100			
zemlja	2,000					400			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						107,1 cm			
U-value supplement				U-value:		0,119		W/(m ² K)	

Assembly no.		08ud				S2* Streha strojne delavnice v naklonu (NI DEL FAZE 1)		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		3-Floor		interior R _{si}		0,17			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB plošča	2,200					220			
naklonski beton	1,600	(od 2 do 17cm)				95			
bitumen	0,190					5			
EPS 031	0,031			(24cm + naklon 0-70cm)		590			
hidroizolacija	0,190					10			
folija	0,190					1			
prodec	1,600					100			
zemlja	2,000					400			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						142,1 cm			
U-value supplement				U-value:		0,051		W/(m ² K)	

Assembly no.		09ud				S3 Streha shrambe orodja		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		1-Roof		interior R _{si}		0,10			
Adjacent to		1-Outdoor air		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
XPS 035	0,035	(npr. Fibran XPS300L)				20			
AB plošča	2,200					220			
naklonski beton	1,600	(od 2 do 5cm)				35			
hidroizolacija	0,190					9			
XPS 035	0,035	(npr. Fibran XPS300L)				200			
folija	0,190					1			
prodec	1,600					50			
zemlja	2,000					260			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						79,5 cm			
U-value supplement				U-value:		0,148		W/(m ² K)	

Assembly no.		10ud				S5 Streha povezovalnega hodnika		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		1-Roof		interior R _{si}		0,10			
Adjacent to		1-Outdoor air		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB plošča	2,200					200			
naklonski beton	1,600	(od 2 do 17cm)				95			
parna zapora	0,190					5			
EPS 031	0,031	(npr. F. NeoSuper100)				240			
hidroizolacija	0,190					10			
folija	0,190					1			
prodec	1,600					100			
zemlja	2,000					400			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						105,1 cm			
U-value supplement				U-value:		0,119 W/(m ² K)			

Assembly no.		11ud				Z1 Kletna stena v terenu		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB kletna stena	2,200					250			
hidroizolacija	0,190					5			
XPS 035	0,035	(npr. Fibran XPS 300L)				220			
zasutje	1,600					500			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						97,5 cm			
U-value supplement				U-value:		0,146 W/(m ² K)			

Assembly no.		12ud				Z2 Stena v koridorju		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		1-Outdoor air		exterior R _{se}		0,04			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB stena	2,200					250			
kamena volna 036	0,036	(StoThermMineral)				250			
omet	0,800					10			
prezračevan koridor									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						51,0 cm			
U-value supplement				U-value:		0,138 W/(m ² K)			

Assembly no.		13ud				Z3 Kletna stena		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB kletna stena	2,200					250			
hidroizolacija	0,190					3			
XPS 035	0,035	(npr. Fibran XPS 300L)		povečana debelina!		220			
beton	1,600					100			
pilotna stena									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
85%		15,0%				57,3 cm			
U-value supplement				U-value:		0,151 W/(m ² K)			

Assembly no.		14ud				Z4 Kletna stena jaška		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB kletna stena	2,200					250			
hidroizolacija	0,190					3			
XPS 035	0,035	(npr. Fibran XPS 300L)				220			
beton	1,600					100			
pilotna stena									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						57,3 cm			
U-value supplement				U-value:		0,151 W/(m ² K)			

Assembly no.		15ud				Z5 Zidovi povezovalnega hodnika		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		2-Ground		exterior R _{se}		0,00			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB kletna stena	2,200					250			
hidroizolacija	0,190					3			
XPS 035	0,035	(npr. Fibran XPS 300L)				220			
beton	1,600					100			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						57,3 cm			
U-value supplement				U-value:		0,151 W/(m ² K)			

Assembly no.		16ud				F1 Lahka fasadna stena telovadnice		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		3-Ventilated		exterior R _{se}		0,13			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
lesene plošče	0,130	(npr. KLH, CLT)				120			
PUR/PIR	0,021	(npr. WeberTherm+UI)				50			
kamena volna 035	0,035	(npr. KI FP 035)				110			
folija	0,190					1			
podkonstrukcija									
fasadna ploč. obloga									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						28,1 cm			
U-value supplement				U-value:		0,149 W/(m ² K)			

Assembly no.		17ud				F1a Masivna fasadna stena pritličja		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		3-Ventilated		exterior R _{se}		0,13			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB stena	2,200					500			
PUR/PIR	0,021	(npr. WeberTherm+UI)				60			
kamena volna 035	0,035	(npr. KI FPL-035)				120			
folija	0,190					1			
podkonstrukcija									
fasadna ploč. obloga									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						68,1 cm			
U-value supplement				U-value:		0,148 W/(m ² K)			

Assembly no.		18ud				F2a Masivna fasadna stena nadstropja		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		3-Ventilated		exterior R _{se}		0,13			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
AB stena	2,200					400			
PUR/PIR	0,021	(npr. WeberTherm+UI)				60			
kamena volna 035	0,035	(npr. KI FPL-035)				120			
folija	0,190					1			
podkonstrukcija									
fasadna lesena obloga									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						58,1 cm			
U-value supplement				U-value:		0,149 W/(m ² K)			

Assembly no.		19ud				F2b Fasadna stena telovadnice		Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element		2-Wall		interior R _{si}		0,13			
Adjacent to		3-Ventilated		exterior R _{se}		0,13			
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
lesene plošče	0,130	(npr. KLH, CLT)				120			
PUR/PIR	0,021	(npr. WeberTherm+UI)				60			
kamena volna 035	0,035	(npr. KI FPL-035)				100			
folija	0,190					1			
podkonstrukcija									
fasadna lesena obloga									
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%						28,1 cm			
U-value supplement				U-value:		0,145 W/(m ² K)			

Assembly no.		20ud						Interior insulation?	
		Heat transmission resistance [m ² K/W]							
Orientation of building element				interior R _{si}					
Adjacent to				exterior R _{se}					
Area section 1	λ [W/(mK)]	Area section 2 (optional)	λ [W/(mK)]	Area section 3 (optional)	λ [W/(mK)]	Thickness [mm]			
Percentage of sec. 1		Percentage of sec. 2		Percentage of sec. 3		Total			
100%									
U-value supplement				U-value:					

Heat losses through the ground

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Building section 1

Ground characteristics			
Thermal conductivity	λ	2,0	W/(mK)
Heat capacity	ρc	2,0	MJ/(m ³ K)
Periodic penetration depth	δ	3,17	m

Climate data			
Avg indoor temp. winter	T_i	20,0	°C
Avg indoor temp. summer	T_i	25,0	°C
Avg ground surface temperature	$T_{g,ave}$	11,8	°C
Amplitude of $T_{g,ave}$	$T_{g,\Delta}$	10,4	°C
Phase shifting of $T_{e,m}$	τ	1,0	Months
Length of the heating period	n	6,2	Months
Heating degree hours - exterior	G_e	71,4	kKh/a

Building data			
Area of ground floor slab / basement A	1509,9	m ²	
Perimeter length	166,5	m	
Charact. dimension of floor slab	18,14	m	
U-value floor slab/basement ceiling	U_f	0,150	W/(m ² K)
TBs floor slab / basement ceiling	$\Psi_{B,*1}$	0,00	W/K
U-value floor slab / basement ceiling i	U_f'	0,150	W/(m ² K)
Equivalent thickness floor	d_f	13,30	m

Floor slab type (select only one)

x Slab on grade			
Perimeter insulation width/depth	D	1,35	m
Perimeter insulation thickness	d_n	0,22	m
Conductivity perimeter insulation	λ_n	0,035	W/(mK)
Orientation of perimeter insulation	horizontal		
(check only one field)	vertical	x	

Heated basement or floor slab completely / partially below ground level			
Basement wall height below ground le Z		m	U-Value wall below ground U_{WB} W/(m ² K)

Unheated basement			
Height aboveground wall	h		U-Value wall above ground U_W W/(m ² K)
Basement wall height below ground le Z		m	U-Value wall below ground U_{WB} W/(m ² K)
Air change unheated basement	n		U-Value basement floor slab U_{fB} W/(m ² K)
Air volume basement	V		

Suspended floor above a ventilated crawl space (at max. 0.5 m below ground)			
U-Value crawl space	U_{Crawl}		Area of ventilation openings εP m ²
Height of crawl space wall	h		Wind velocity at 10 m height v m/s
U-Value crawl space wall	U_W		Wind shield factor f_W -

Additional thermal bridge heat losses at perimeter			
Phase shift	β		Months
Steady-state fraction	$\Psi_{P,stat,*1}$		W/K
Harmonic fraction	$\Psi_{P,harm,*1}$		W/K

Groundwater correction			
Depth of the groundwater table	z_w	3,0	m
Groundwater flow rate	q_w	0,05	m/d
Groundwater correction factor	G_w	1,14058875	-

Interim results

Phase shift	β	1,41	Months	Steady-state heat flow	Φ_{stat}	1253,0	W
Steady-state transmittance	L_S	153,27	W/K	Periodic heat flow	Φ_{harm}	92,2	W
Exterior periodic transmittance	L_{pe}	19,46	W/K	Heat losses during heating period	Q_{tot}	6057	kWh
Transmittance building	L_0	227,10	W/K				

Monthly average temperatures in the ground for monthly method (building assembly 1)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Avg. value
Winter	13,8	13,6	13,6	13,9	14,3	14,8	15,1	15,4	15,3	15,1	14,7	14,2	14,5
Summer	15,4	15,2	15,3	15,5	15,9	16,4	16,8	17,0	17,0	16,7	16,3	15,8	16,1

Design ground temperature for 'Heating load' worksheet For 'Cooling load' worksheet

Reduction factor for 'Annual heating' worksheet

Total result (all building parts)

Phase shift	β	1,41	Months	Steady-state heat flow	Φ_{stat}	1253,0	W
Steady-state transmittance	L_S	153,27	W/K	Periodic heat flow	Φ_{harm}	92,2	W
Exterior periodic transmittance	L_{pe}	19,46	W/K	Heat losses during heating period	Q_{tot}	6057	kWh
Transmittance building	L_0	227,10	W/K	Charact. dimension of floor slab	B'	18,14	m

Monthly Average temperatures in the ground for monthly method (all building assemblies)

Month	1	2	3	4	5	6	7	8	9	10	11	12	Avg. value
Winter	13,8	13,6	13,6	13,9	14,3	14,8	15,1	15,4	15,3	15,1	14,7	14,2	14,5
Summer	15,4	15,2	15,3	15,5	15,9	16,4	16,8	17,0	17,0	16,7	16,3	15,8	16,1

Design ground temperature for 'Heating load' worksheet For 'Cooling load' worksheet

Reduction factor for 'Annual heating' worksheet

Areas determination

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m²K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment				
	Treated floor area	1	2043,07	m²	Treated floor area according to PHPP manual				
A	North windows	2	5,04	m²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,903	248	407
A	East windows	3	182,00	m²		East windows	0,871	11093	20741
A	South windows	4	0,00	m²		South windows			
A	West windows	5	75,60	m²		West windows	0,842	2372	12002
A	Horizontal windows	6	0,00	m²		Horizontal windows			
A	Exterior door	7	37,04	m²	Please subtract area of door from respective building assembly	Exterior door	0,900		
A	External wall - Ambient	8	1269,41	m²	Temperature zone "A" is ambient air	External wall - Ambient	0,145	279	670
B	External wall - Ground	9	122,56	m²	Temperature zone "B" is the ground	External wall - Ground	0,151		
A	Roof/Ceiling - Ambient	10	1590,73	m²		Roof/Ceiling - Ambient	0,118	175	1889
B	Floor slab / Basement ceiling	11	1585,53	m²		Floor slab / Basement ceiling	0,148		
		12	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
		13	0,00	m²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
X		14	0,00	m²	Temperature zone "X": Please provide user-defined reduction factor (0 < ft < 1):				
						Thermal bridges - Overview	Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	167,00	m	Units in m	Thermal bridges Ambient	0,050		
P	Perimeter thermal bridges	16	211,90	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,150		
B	Thermal bridges FS/BC	17	239,60	m	Units in m	Thermal bridges FS/BC	0,150		
I	Building element towards neighbour	18	0,00	m²	No heat losses, only considered for the heating load calculation	Building element towards neighbour			
Total thermal envelope						Average therm. envelope	0,197		

[Go to building components list](#)

Area input													1-Sorting: AS LIST												
Area no.	Building assembly description	To group No.	Assigned to group	Quantity	x (a [m]	x	b [m]	+	User determined [m²]	-	User subtraction [m²]	-	Subtraction window areas [m²]) =	Area [m²]	Selection building assembly / Building system	U-Value [W/(m²K)]	Deviation from North	Angle of inclination from the horizontal	Orientation	Reduction factor shading	Exterior absorptivity	Exterior emissivity	
	Projected building footprint	0	Projected building footprint	1	x (+	1588,13	-)		=	1588,1									
	Treated floor area	1	Treated floor area	1	x (+	2043,07	-)		=	2043,1									
	Exterior door	7	Exterior door	1	x (+		-)		=		Exterior door								
1	Neto prostornina			1	x (+	12935,40	-)		=										
2	Svetla višina povprečno			1	x (+	6,33	-)		=										
3				1	x (56,60	x	26,50	+		-)		=										
4				1	x (22,25	x	21,15	+		-	4,17)		=										
5				1	x (6,75	x	8,85	+		-)		=										
6	tla na terenu skupaj			1	x (+	2026,06	-)		=										
7	obseg			1	x (+	224,20	-)		=										
8				1	x (+		-)		=										
9				1	x (+		-)		=										
10	streha povezovalnega dela	10	Roof/Ceiling - Ambient	1	x (5,35	x	3,25	+		-)		=	17,4	10ud-S5 Streha povezovalnega hodnika	0,119	240	0	Hor	0,40	0,60	0,90	
11	tla povezovalnega dela	11	Floor slab / Basement ceiling	1	x (4,55	x	3,25	+		-)		=	14,8	05ud-N5 Tla povezovalnega hodnika	0,141							
12	tla povezovalnega dela	10	Roof/Ceiling - Ambient	1	x (0,80	x	3,25	+		-)		=	2,6	05ud-N5 Tla povezovalnega hodnika	0,141	240	0	Hor	0,10	0,60	0,90	
13	stena povezovalnega dela	9	External wall - Ground	1	x (5,35	x	3,25	+		-)		=	17,4	15ud-Z5 Zidovi povezovalnega hodnika	0,151							
14				1	x (+		-)		=										
15	stena delavnic proti koridorju	8	External wall - Ambient	0	x (22,35	x	6,55	+		-)		=	0,0	12ud-Z2 Stena v koridorju	0,138	240	90	West	0,10	0,60	0,90	
16	stena delavnic proti skladišču	8	External wall - Ambient	0	x (9,30	x	5,70	+		-)		=	0,0	12ud-Z2 Stena v koridorju	0,138	330	90	North	0,10	0,60	0,90	
17	stena delavnic proti prehodu	8	External wall - Ambient	0	x (11,95	x	4,85	+		-	0,00)		=	0,0	17ud-F1a Masivna fasadna stena pritličja	0,148	330	90	North	0,10	0,60	0,90	
18	stena delavnic SV	8	External wall - Ambient	0	x (21,90	x	4,85	+		-)		=	0,0	17ud-F1a Masivna fasadna stena pritličja	0,148	60	90	East	0,70	0,60	0,90	
19	tla na terenu delavnice	11	Floor slab / Basement ceiling	0	x (22,25	x	21,15	+		-	4,17)		=	0,0	04ud-P4 Strojne delavnice, skladišče, ročna delavnica, kabinet	0,149							
20	streha delavnic ravni del	10	Roof/Ceiling - Ambient	0	x (10,80	x	21,90	+		-)		=	0,0	07ud-S2 Streha strojne delavnice	0,119	60	0	Hor	0,70	0,60	0,90	
21	streha delavnic poševnina	10	Roof/Ceiling - Ambient	0	x (+	0,00	-	0,00)		=	0,0	08ud-S2* Streha strojne delavnice v naklonu	0,051	60	20	Hor	0,80	0,60	0,90	
22				1	x (+		-)		=										

Areas determination

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m ² K)]	Radiation-gains heating season [kWh/a]	Radiation-load cooling period [kWh/a]
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment				
	Treated floor area	1	2043,07	m ²	Treated floor area according to PHPP manual				
A	North windows	2	5,04	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,903	248	407
A	East windows	3	182,00	m ²		East windows	0,871	11093	20741
A	South windows	4	0,00	m ²		South windows			
A	West windows	5	75,60	m ²		West windows	0,842	2372	12002
A	Horizontal windows	6	0,00	m ²		Horizontal windows			
A	Exterior door	7	37,04	m ²	Please subtract area of door from respective building assembly	Exterior door	0,900		
A	External wall - Ambient	8	1269,41	m ²	Temperature zone "A" is ambient air	External wall - Ambient	0,145	279	670
B	External wall - Ground	9	122,56	m ²	Temperature zone "B" is the ground	External wall - Ground	0,151		
A	Roof/Ceiling - Ambient	10	1590,73	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Roof/Ceiling - Ambient	0,118	175	1889
B	Floor slab / Basement ceiling	11	1585,53	m ²		Temperature zones "A", "B", "P" and "X" may be used. NOT "I"	Floor slab / Basement ceiling	0,148	
		12	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
		13	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"				
X		14	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < f < 1):				
						Thermal bridges - Overview	Ψ [W/(mK)]		
A	Thermal bridges Ambient	15	167,00	m	Units in m	Thermal bridges Ambient	0,050		
P	Perimeter thermal bridges	16	211,90	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,150		
B	Thermal bridges FS/BC	17	239,60	m	Units in m	Thermal bridges FS/BC	0,150		
I	Building element towards neighbour	18	0,00	m ²	No heat losses, only considered for the heating load calculation	Building element towards neighbour			
Total thermal envelope						Average therm. envelope	0,197		

Go to building components list

23	stena dvorane proti koridor.	8	External wall - Ambient	1	x (59,05	x	7,80	+		-)	-	75,6	=	385,0	12ud-Z2 Stena v koridorju	0,138	240	90	West	0,10	0,60	0,90	
24	stena dvorane nad koridor.	8	External wall - Ambient	1	x (59,05	x	2,80	+		-)	-	0,0	=	165,3	19ud-F2b Fasadna stena telovadnice	0,145	240	90	West	0,70	0,60	0,90	
25					x (x		+		-)	-	0,0	=										
26	stena jedro pritličje SZ	8	External wall - Ambient	1	x (4,80	x	5,55	+		-	7,26)	-	0,0	=	19,4	17ud-F1a Masivna fasadna stena pritličja	0,148	330	90	North	0,70	0,60	0,90	
27	stena jedro nadstropje SZ	8	External wall - Ambient	1	x (10,20	x	26,80	+	-6,00	-	137,61)	-	5,0	=	124,7	18ud-F2a Masivna fasadna stena nadstropja	0,149	330	90	North	0,70	0,60	0,90	
28	stena dvorana pritličje SV	8	External wall - Ambient	1	x (3,90	x	56,60	+		-	17,40)	-	36,8	=	166,5	16ud-F1 Lahka fasadna stena telovadnice	0,149	60	90	East	0,70	0,60	0,90	
29	stena dvorana nadstrop. SV	8	External wall - Ambient	1	x (3,85	x	56,60	+		-)	-	145,2	=	72,7	18ud-F2a Masivna fasadna stena nadstropja	0,149	60	90	East	0,70	0,60	0,90	
30	stena dvorana nadstrop. SV	8	External wall - Ambient	1	x (2,25	x	56,60	+		-)	-	0,0	=	127,4	19ud-F2b Fasadna stena telovadnice	0,145	60	90	East	0,70	0,60	0,90	
31	stena dvorane pritličje JV	8	External wall - Ambient	1	x (8,15	x	3,50	+		-)	-	0,0	=	28,5	17ud-F1a Masivna fasadna stena pritličja	0,148	150	90	South	0,50	0,60	0,90	
32	stena dv. vkop. pritličje JV	9	External wall - Ground	1	x (9,60	x	3,50	+		-)	-	0,0	=	33,6	14ud-Z4 Kletna stena jaška	0,151	150	90	South				
33	stena dvorane nadstropje JV	8	External wall - Ambient	1	x (26,70	x	6,70	+		-	3,96)	-	0,0	=	174,9	18ud-F2a Masivna fasadna stena nadstropja	0,149	150	90	South	0,70	0,60	0,90	
34	tla na terenu	11	Floor slab / Basement ceiling	1	x (35,40	x	26,70	+		-)	-	0,0	=	945,2	01ud-P2 Športna dvorana, igrišče	0,150	60	0	Hor				
35	tla na terenu	11	Floor slab / Basement ceiling	1	x (21,15	x	26,70	+		-)	-	0,0	=	564,7	03ud-P3 Garderobe, sanitarije, komunikacije, lakirnica	0,146	60	0	Hor				
36	streha dvorane	10	Roof/Ceiling - Ambient	1	x (x		+	1509,89	-)	-	0,0	=	1509,9	06ud-S1 Ravna streha nad telovadnico	0,117	60	0	Hor	0,80	0,60	0,90	
37					x (x		+		-)	-	0,0	=										
38	tla ostalo	11	Floor slab / Basement ceiling	1	x (6,80	x	8,95	+		-)	-	0,0	=	60,9	02ud-P2a Športna dvorana, ostale površine	0,138	60	0	Hor				
39	streha ostalo	10	Roof/Ceiling - Ambient	1	x (6,80	x	8,95	+		-)	-	0,0	=	60,9	09ud-S3 Streha shrambe orodja	0,148	60	0	Hor	0,10	0,60	0,90	
40	zunanja stena ostalo SV	8	External wall - Ambient	1	x (2,10	x	3,50	+		-	2,42)	-	0,0	=	4,9	17ud-F1a Masivna fasadna stena pritličja	0,148	60	90	East	0,70	0,60	0,90	
41	vkopana stena ostalo SV	9	External wall - Ground	1	x (4,70	x	3,50	+		-)	-	0,0	=	16,5	11ud-Z1 Kletna stena v terenu	0,146	60	90	East				
42	vkopana stena ostalo JV	9	External wall - Ground	1	x (8,95	x	3,50	+		-)	-	0,0	=	31,3	13ud-Z3 Kletna stena	0,151	150	90	South				
43	vkopana stena ostalo JZ	9	External wall - Ground	1	x (6,80	x	3,50	+		-)	-	0,0	=	23,8	13ud-Z3 Kletna stena	0,151	240	90	West				
44					x (x		+		-)	-	0,0	=										
45	P V1	7	Exterior door	0	x (2,20	x	3,30	+		-)	-	0,0	=	0,0	93ud-Outer door Ud<0,9	0,900	330	90	North	0,10	0,60	0,90	
46	1N V13	7	Exterior door	1	x (3,00	x	2,00	+		-)	-	0,0	=	6,0	93ud-Outer door Ud<0,9	0,900	330	90	North	0,70	0,60	0,90	
47	P V5	7	Exterior door	1	x (2,20	x	3,30	+		-)	-	0,0	=	7,3	93ud-Outer door Ud<0,9	0,900	330	90	North	0,70	0,60	0,90	
48	P V18	7	Exterior door	1	x (2,00	x	3,20	+		-)	-	0,0	=	6,4	93ud-Outer door Ud<0,9	0,900	60	90	East	0,70	0,60	0,90	
49	P V40 V46	7	Exterior door	2	x (2,50	x	2,20	+		-)	-	0,0	=	11,0	93ud-Outer door Ud<0,9	0,900	60	90	East	0,70	0,60	0,90	
50	1N V17	7	Exterior door	1	x (1,80	x	2,20	+		-)	-	0,0	=	4,0	93ud-Outer door Ud<0,9	0,900	150	90	South	0,70	0,60	0,90	
51	P V47	7	Exterior door	1	x (1,10	x	2,20	+		-)	-	0,0	=	2,4	93ud-Outer door Ud<0,9	0,900	60	90	East	0,30	0,60	0,90	

Areas determination

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Summary						Building assembly overview	Average U-value [W/(m ² K)]	Radiation-gains heating season [kWh/a] 8 Months
Temp.-zone	Area group	Group no.	Area / Length	Unit	Comment			
	Treated floor area	1	2043,07	m ²	Treated floor area according to PHPP manual			
A	North windows	2	5,04	m ²	Results come from the 'Windows' worksheet. Window areas are subtracted from individual opaque areas, which is displayed in the 'Windows' worksheet.	North windows	0,903	248
A	East windows	3	182,00	m ²		East windows	0,871	11093
A	South windows	4	0,00	m ²		South windows		
A	West windows	5	75,60	m ²		West windows	0,842	2372
A	Horizontal windows	6	0,00	m ²		Horizontal windows		
A	Exterior door	7	37,04	m ²		Please subtract area of door from respective building assembly	Exterior door	0,900
A	External wall - Ambient	8	1269,41	m ²	Temperature zone "A" is ambient air	External wall - Ambient	0,145	279
B	External wall - Ground	9	122,56	m ²	Temperature zone "B" is the ground	External wall - Ground	0,151	
A	Roof/Ceiling - Ambient	10	1590,73	m ²		Roof/Ceiling - Ambient	0,118	175
B	Floor slab / Basement ceiling	11	1585,53	m ²		Floor slab / Basement ceiling	0,148	
		12	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
		13	0,00	m ²	Temperature zones "A", "B", "P" and "X" may be used. NOT "I"			
X		14	0,00	m ²	Temperature zone "X": Please provide user-defined reduction factor (0 < ft < 1):	Factor for X		
						Thermal bridges - Overview	Ψ [W/(mK)]	
A	Thermal bridges Ambient	15	167,00	m	Units in m	Thermal bridges Ambient	0,050	
P	Perimeter thermal bridges	16	211,90	m	Units in m; temperature zone "P" is perimeter (see 'Ground' worksheet)	Perimeter thermal bridges	0,150	
B	Thermal bridges FS/BC	17	239,60	m	Units in m	Thermal bridges FS/BC	0,150	
I	Building element towards neigh	18	0,00	m ²	No heat losses, only considered for the heating load calculation	Building element towards neighbour		
Total thermal envelope			4867,92	m²		Average therm. envelope	0,197	

[Go to building components list](#)


Thermal bridge inputs																
No.	Thermal bridge - denomination	Group No.	Assigned to group	Quantity	x (Length [m]	-	Subtraction length [m])=	Length ℓ [m]	User determined psi value [W/(mK)]	User determined f _{Rsi=0,25} (optional)	or	Selection building system	Ψ-Value [W/(mK)]	f _{Rsi} -Requirement met?
2	temeljni perimetr	16	Perimeter thermal bridges	2	x (27,05	-)=	54,10	0,150			or		0,150	
3	temeljni znotraj	17	Thermal bridges FS/BC	3	x (19,10	-)=	57,30	0,150			or		0,150	
4	temeljni znotraj	17	Thermal bridges FS/BC	5	x (24,70	-)=	123,50	0,150			or		0,150	
5	temeljni znotraj	17	Thermal bridges FS/BC	3	x (19,60	-)=	58,80	0,150			or		0,150	
6	atika dvoranski del	15	Thermal bridges Ambient	2	x (56,70	-)=	113,40	0,050			or		0,050	
7	atika dvoranski del	15	Thermal bridges Ambient	2	x (26,80	-)=	53,60	0,050			or		0,050	
8	atika delavnice	15	Thermal bridges Ambient	0	x (21,90	-)=	0,00	0,100			or		0,100	
9	atika delavnice	15	Thermal bridges Ambient	0	x (21,30	-)=	0,00	0,100			or		0,100	
10					x (-)=					or			
11					x (-)=					or			
12					x (-)=					or			
13					x (-)=					or			
14					x (-)=					or			
15					x (-)=					or			
16					x (-)=					or			
17					x (-)=					or			
18					x (-)=					or			
19					x (-)=					or			
20					x (-)=					or			
21					x (-)=					or			
22					x (-)=					or			
23					x (-)=					or			
24					x (-)=					or			
25					x (-)=					or			
26					x (-)=					or			
27					x (-)=					or			
28					x (-)=					or			
29					x (-)=					or			
30					x (-)=					or			
31					x (-)=					or			
32					x (-)=					or			
33					x (-)=					or			

Windows

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Window area orientation	Global radiation (main orientations) kWh/(m²a)	Shading	Dirt	Non-vertical radiation incidence	Glazing fraction	g-Value	Solar irradiation reduction factor	Window area m²	Window U-Value W/(m²K)	Glazing area m²	Average global radiation kWh/(m²a)
Standard values →	94	0,75	0,95	0,85	0,71	0,54	0,53	5,04	0,90	3,59	109
North	201	0,91	0,95	0,85	0,71	0,54	0,52	182,00	0,87	128,73	137
East	383	1,00	0,95	0,85	0,00	0,00	0,00	0,00	0,00	0,00	383
South	215	0,22	0,95	0,85	0,75	0,54	0,13	75,60	0,84	56,48	294
West	322	1,00	0,95	0,85	0,00	0,00	0,00	0,00	0,00	0,00	322
Horizontal											
Total or average value for all windows.						0,54	0,41	262,64	0,86	188,80	

Transmission losses heating period kWh/a	Heating gains solar radiation heating period kWh/a
325	158
11315	6964
0	0
4544	1580
0	0
16184	8702



Recommendation for U_{w,installed} [W/(m²K)]

0,85	1,00	1,10	0,52
------	------	------	------

Heating degree hours [kWh/a]: 71,4

[Go to glazing list](#) [Go to window frames list](#)

Quantity	Description	Deviation from north	Angle of inclination from the horizontal	Orientation	Window rough openings		Installed in	Glazing	Frame	g-Value	U-Value		Ψ Glazing edge (Avg.)	Installation situation				Ψ _{Installation} (Avg.)	Results				
					Width	Height					Perpendicular radiation	Glazing		Frames (avg.)	user determined value for Ψ _{Installation} of '1': Ψ _{Installation} from 'Components' worksheet '0': in the case of abutting windows				Window Area	Glazing area	U _{w, installed}	Glazed fraction per window	
															left	right	bottom						top
0	po7 po6 po5	60	90	East	1,625	1,800	18-stena delavnice SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,13	0,039	0	1	1	1	0,025					
0		60	90	East	1,625	1,800	18-stena delavnice SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,13	0,039	0	0	1	1	0,025					
0		60	90	East	1,625	1,800	18-stena delavnice SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,13	0,039	1	0	1	1	0,025					
0	o13 o14 o15	240	90	West	1,625	1,000	15-stena delavnice proti koridorju	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,14	0,039	0	1	1	1	0,025					
0		240	90	West	1,625	1,000	15-stena delavnice proti koridorju	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,14	0,039	0	0	1	1	0,025					
0		240	90	West	1,625	1,000	15-stena delavnice proti koridorju	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,14	0,04	1	0	1	1	0,025					
2	o12 o12b	330	90	North	1,200	2,100	27-stena jedro nadstropje SZ	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	1	1	1	1	0,025	5,0	3,6	0,9	0,7	
4	o4 o3 o2 o1	60	90	East	1,000	2,300	28-stena dvorane pritličje SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	0	1	1	1	0,025	9,2	6,3	0,9	0,7	
8		60	90	East	1,000	2,300	28-stena dvorane pritličje SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	0	0	1	1	0,025	18,4	12,6	0,9	0,7	
4		60	90	East	1,000	2,300	28-stena dvorane pritličje SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	1	0	1	1	0,025	9,2	6,3	0,9	0,7	
11	o11 do o1	60	90	East	1,000	3,300	29-stena dvorane nadstrop. SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,11	0,04	0	1	1	1	0,025	36,3	25,9	0,9	0,7	
22		60	90	East	1,000	3,300	29-stena dvorane nadstrop. SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,11	0,04	0	0	1	1	0,025	72,6	51,7	0,9	0,7	
11		60	90	East	1,000	3,300	29-stena dvorane nadstrop. SV	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,11	0,04	1	0	1	1	0,025	36,3	25,9	0,9	0,7	
6	o18 do o24	240	90	West	1,500	2,100	23-stena dvorane proti koridor.	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	0	1	1	1	0,025	18,9	14,1	0,9	0,7	
12		240	90	West	1,500	2,100	23-stena dvorane proti koridor.	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	0	0	1	1	0,025	37,8	28,2	0,8	0,7	
6		240	90	West	1,500	2,100	23-stena dvorane proti koridor.	01ud-Trojna zastek. Ug=0.60 g=54%	01ud-Uf < 1,1/1,2	0,54	0,60	1,12	0,04	1	0	1	1	0,025	18,9	14,1	0,9	0,7	

Ventilation data

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Treated floor area A_{TFA}	m ²	2043	(Areas' worksheet)
Room height h	m	6,33	6,33
Volume of ventilated space ($A_{TFA} \cdot h$) V_V	m ³	12935	(Worksheet 'Annual heating')

Ventilation type

Please select **1-Balanced PH ventilation with HR**

Infiltration air change rate

Wind protection coefficients e and f		
Coefficient e for wind protection class	Several side exposed	One side exposed
No protection	0,10	0,03
Moderate protection	0,07	0,02
High protection	0,04	0,01
Coefficient f	15	20

Wind protection coefficient, e		For annual demand: 0,07	For heating load: 0,18		
Wind protection coefficient, f		15	15	Net air volume for press. test V_{n50}	Air permeability q_{50}
Air change rate at press. test n_{50}	1/h	0,60	0,60	12935 m ³	1,59 m ³ /(hm ²)
Excess extract air	1/h	0,00	0,00		
Infiltration air change rate $n_{V,Rest}$	1/h	0,042	0,105		

Selection of ventilation input - Results

PHPP offers two methods for dimensioning air quantities and choosing the ventilation unit. With "Standard data input for balanced ventilation", supply or extract air quantities for residential buildings and parameters for ventilation systems with a maximum of 1 ventilation unit can be planned. Projects with up to 10 different ventilation units and air quantities determined according to rooms or zones can be entered in the 'Addl vent' worksheet. Please select your design method here:

Ventilation unit / Heat recovery efficiency design		Average air flow rate m ³ /h	Average air change rate 1/h	Extract air excess (extract air system) 1/h	Effective heat recovery efficiency unit [-]	Humidity recovery efficiency [-]	Specific power input Wh/m ³	Heat recovery efficiency SHX [-]
<input checked="" type="checkbox"/>	Standard design (Ventilation' worksheet, see below)	6000	0,46	0,00	91,8%	0,0%	0,27	0,0%
<input type="checkbox"/>	Multiple ventilation units, non-res (Addl vent' worksheet)							
Cooling recovery							Efficiency SHX	0%

Average interior humidity during winter operation

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
35%	35%	41%	49%	-	-	-	-	69%	59%	46%	36%

Extended input for balanced ventilation (at the moment this worksheet is inactive. Calculation takes place in the 'Ventilation' worksheet.)

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Planning ventilation systems with multiple ventilation units

Ventilation unit / Heat recovery efficiency design
In Ventilation sheet (standard design)
In 'Addl vent worksheet (this worksheet)

x	(Ventilation' worksheet)
0,0	(Addl vent)

Treated floor area A_{TFA}

m² 2043 (Areas' worksheet)

Room height h

m 6,33 (Worksheet 'Annual heating')

Room air volume for ventilation (A_{TFA}·h) = V_V

m³ 12935 (Worksheet 'Annual heating')

Number of occupants

P 150,0 (Ventilation' worksheet)

Room temperature

°C 20 (Worksheet 'Annual heating')

Average external temp. heating period

°C 4,9 (Ventilation' worksheet)

Average ground temp.

°C 11,8 (Ground' worksheet)

Length of the heating period

d/a 188 (Heating' worksheet)

Ventilation type

1-Balanced PH ventilation with HR (Ventilation' worksheet)

Results of ventilation design and unit selection:

Ventilation unit no.	Description of the unit	Design		Annual average value		
		V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{SUP} m ³ /h	V _{ETA} m ³ /h	Air ch.rt. 1/h
1	klimat dvorana	15480	15480	2996	2996	---
2	klimat dvorana jug	19590	19590	3538	3538	---
3	klimat bar	1320	1320	234	234	---
4	klimat klub	4050	4050	718	718	---
5	klimat fitnes	660	660	117	117	---
6	klimat sanitarije	600	600	106	106	---
7	klimat plesna	540	540	96	96	---
8	klimat več. Prostor	450	450	80	80	---
9	ostali prostori	100	1000	18	177	---
10						---

Result for overall vent. syst:

--	--	--	--	--

Effective heat recovery efficiency	Humidity recovery efficiency	Spec. input power	Heat recov. efficiency SHX
79%	58%	0,20	0%
79%	58%	0,20	0%
84%	0%	0,26	0%
85%	0%	0,29	0%
85%	0%	0,19	0%
80%	0%	0,14	0%
83%	0%	0,10	0%
83%	0%	0,10	0%
0%	0%	0,10	0%

--	--	--	--

Recommendations for dimensioning air quantities

Use of low odour and low VOCs building materials/furnishings:

It is strongly recommended to use building materials that cause no or very low VOCs/odours instead of increasing the outdoor air volume in order to clear the air.

This holds true independently from the chosen approach to determine air quality; emissions of all sources in the room should be considered, e.g. furniture, carpets and ventilation or air-conditioning unit.

Assessment of volume flow rates according to the number of persons

Also in non-residential buildings, the number of persons is fundamentally important for assessing the volume air flow rates. For good indoor air quality volumes between 20 to 30 m³/h/person are sufficient.

Higher outdoor air amounts may lead to excessively dry indoor air in winter. The air flow rates are specified by classification according to EN 13779. The classification must be agreed with the client in advance.

IDA 3 is adequate for office buildings. IDA 4 has proven satisfactory for school buildings as flushing ventilation is carried out during breaks anyway. For typical outdoor air CO₂ concentrations of around 400-500 ppm, it is possible to comply even with 1500 ppm. Exceeding this figure temporarily is permissible.

Outdoor air flow rates per person:

- Recommended for residential buildings: around 30 m³/(h person)
- Recommended for offices and similar uses: around 30 m³/(h person) (AMEV: 28 m³/(h person); EN 13779 / IDA 3: at least 24 m³/(h person))
- Recommended for schools and day care centres: 15 to 20 m³/(h person) (Source: Guidelines for energy-efficient educational buildings, Passive House Institute, 2010)
- Recommendation for sport halls: 60 m³/(h person) (DIN 18032-1)

Flushing phase for intermittent ventilation operation

In case the ventilation is to be used intermittently (turned off at night), then it should be flushed in the morning, approx. 1 to 2 hours before building is occupied. This should be done in order to refresh air from emissions such as VOCs. Flushing the building causes that the ventilation system works for a longer period (utilisation time + flushing phase). Please consider this at design stage.

Dimensioning of air quantities

When dimensioning the air quantities, please consider the design recommendations given above.

The operation period of the ventilation can be determined on the basis of daily utilisation hours, including flushing phase if applicable. In addition, time periods with reduced ventilation requirements (operation modes) can be taken into account by means of reduction factors.

Room no.	Amount a	Room name	Allocation to ventilation unit (No.)	Area A m ²	Clear height h m	Room vol. A x h m ³	Volume flow per room			Air chng. rt. per room n 1/h	Utilisation times h/d h	d/week d	Duration of holidays d	Reduction factor 1	Operation red. 1	Reduction factor 2	Operation red. 2	Reduction factor 3	Operation red. 3	Annual average value:			
							V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h											V _{SUP} m ³ /h	V _{ETA} m ³ /h	V _{TRANS} m ³ /h	Change rate 1/h
1	1	Dvorana - sever	1	952	9,78	9311	15480	15480		1,66	15	7	115	80%	100%					2996	2996		0,32
2	1	Dvorana - jug	2	1152	8,29	9551	19590	19590		2,05	14	7	115	80%	100%					3538	3538		0,37
3	1	bar	3	271	4,22	1142	1320	1320		1,16	11	7	115	100%	100%					234	234		0,21
4	1	klub	4	677	3,00	2030	4050	4050		1,99	11	7	115	100%	100%					718	718		0,35
5	1	fitnes	5	123	3,74	459	660	660		1,44	11	7	115	100%	100%					117	117		0,26
6	1	sanitarije - pritičje	6	162	3,17	514	600	600		1,17	11	7	115	100%	100%					106	106		0,21
7	1	plesna dvorana	7	93	3,00	279	540	540		1,93	11	7	115	100%	100%					96	96		0,34
8	1	večnamenski prostor	8	74	4,20	311	450	450		1,45	11	7	115	100%	100%					80	80		0,26
9	1	ostalo	9	795	3,33	2647	100	1000		0,38	11	7	115	100%	100%					18	177		0,07
10																							
11																							
12																							
13																							
14																							
15																							
16																							
17																							
18																							
19																							
20																							
21																							
22																							
23																							
24																							
25																							
26																							
27																							
28																							
29																							
30																							
Additional lines: Please mark complete lines above, copy and paste multiple times																				7903	8063	---	0,30

Specific energy for heating (monthly method)

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

The sum of the heating periods calculated through the monthly method will be presented on this side.

Interior temperature: °C
 Building type:
 Treated floor area A_{TFA}: m²
 Spec. Capacity: Wh/(m²K)

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Month. red. fac.	G _t kWh/a	Per m ² of treated floor area kWh/(m ² a)	
External wall - Ambient	A	1269,4	0,145	1,00	81 = 14850	7,27	
External wall - Ground	B	122,6	0,151	1,00	33 = 613	0,30	
Roof/Ceiling - Ambient	A	1590,7	0,118	1,00	81 = 15238	7,46	
Floor slab / Basement ceiling	B	1585,5	0,148	1,00	33 = 7798	3,82	
	A			1,00			
	A			1,00			
	X			0,00			
Windows	A	262,6	0,863	1,00	81 = 18354	8,98	
Exterior door	A	37,0	0,900	1,00	81 = 2698	1,32	
Exterior TB (length/m)	A	167,0	0,050	1,00	81 = 676	0,33	
Perimeter TB (length/m)	P	211,9	0,150	1,00	33 = 1055	0,52	
Ground TB (length/m)	B	239,6	0,150	1,00	33 = 1193	0,58	
Total						62474	30,6

Transmission heat losses Q _T	Effective air volume V _V m ³	A _{TFA} m ²	Clear room height m	Effective air change rate Ambient n _{V,e} 1/h	Effective air change rate Ground n _{V,g} 1/h	η*SHX	η _{HR}	n _{V,Res} 1/h	n _{V,equi.fraction} 1/h	V _V m ³	n _{V,equi.fraction} 1/h	C _{Air} Wh/(m ² K)	G _t kWh/a	Per m ² of treated floor area kWh/(m ² a)	
	2043	2043	6,33	0,464	0,464	0%	0,92	0,042	0,080	12935	0,080	0,33	81 = 27722	13,6	
						0%	0,92		0,000	12935	0,000	0,33	47 = 0	0,0	
Total														27722	13,6

Total heat losses Q _L	Q _T kWh/a	Q _V kWh/a	Reduction factor night/weekend saving	Per m ² of treated floor area kWh/(m ² a)
	62474	27722	1,0	44,1

Orientation of the area	Reduction factor see 'Windows' worksheet	g-Value (perp. radiation)	Area m ²	Global radiation kWh/(m ² a)	Per m ² of treated floor area kWh/(m ² a)	
North	0,53	0,54	5,0	172	248	
East	0,52	0,54	182,0	218	11093	
South	0,00	0,00	0,0	546	0	
West	0,13	0,54	75,6	441	2372	
Horizontal	0,00	0,00	0,0	509	0	
Sum opaque areas					3352	
Total					17064	8,4

Internal heat gains Q _I	Length Heat. Period kh/d	Spec. Power q _i W/m ²	A _{TFA} m ²	Per m ² of treated floor area kWh/(m ² a)	
	0,024	242	2043,1	12,2	
Free heat Q _F				41983	20,5
Ratio free heat to losses				0,47	
Utilisation factor heat gains h ₆				96%	
Heat gains Q _G				40158	19,7

Annual heating demand Q _H	Per m ² of treated floor area kWh/(m ² a)
	24
Limiting value	-
Requirement met?	-


Specific energy for heating (monthly method)

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Interior temperature: **20** °C
 Building type: **Športna dvorana**
 Treated floor area A_{TFA}: **2043** m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating degree hours - External	15,2	12,4	10,5	7,3	3,3	0,6	-0,1	-0,2	3,7	6,7	10,5	14,7	84	kKh
Heating degree hours - Ground	4,6	4,3	4,7	4,4	4,2	2,6	2,4	2,2	3,4	3,7	3,8	4,3	45	kKh
Losses - Exterior	14928	12202	10309	7132	3199	598	-113	-206	3587	6587	10344	14449	83015	kWh
Losses - Ground	1476	1378	1519	1412	1361	836	772	722	1081	1177	1233	1384	14350	kWh
Sum spec. losses	8,0	6,6	5,8	4,2	2,2	0,7	0,3	0,3	2,3	3,8	5,7	7,7	47,7	kWh/m ²
Solar gains - North	14	25	42	61	77	80	81	70	46	32	17	11	556	kWh
Solar gains - East	658	1087	2130	2733	3842	3938	4276	3406	2272	1199	576	439	26555	kWh
Solar gains - South	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar gains - West	214	259	373	449	498	496	533	524	424	311	195	147	4424	kWh
Solar gains - Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar gains - Opaque	233	339	586	750	963	994	1064	911	648	409	222	164	7284	kWh
Internal heat gains	3192	2883	3192	3089	3192	3089	3192	3192	3089	3192	3089	3192	37584	kWh
Sum spec. gains solar + internal	2,1	2,2	3,1	3,5	4,2	4,2	4,5	4,0	3,2	2,5	2,0	1,9	37,4	kWh/m ²
Utilisation factor	100%	100%	100%	100%	53%	17%	7%	6%	72%	100%	100%	100%	62%	
Annual heating demand	12093	8987	5505	1476	0	0	0	0	1	2619	7478	11879	50038	kWh
Spec. heating demand	5,9	4,4	2,7	0,7	0,0	0,0	0,0	0,0	0,0	1,3	3,7	5,8	24,5	kWh/m ²



Annual heating demand: Comparison

Monthly method	(<i>Heating</i>)	50038 kWh/a	24,5 kWh/(m ² a) reference to treated floor area according to PHPP
Annual method	(<i>Annual heating</i>)	50782 kWh/a	24,9 kWh/(m ² a) reference to treated floor area according to PHPP
		- kWh/a	- kWh/(m ² a)

Heating load

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Interior temperature: °C
 Building type:
 Treated floor area A_{TFA}: m²

Design temperature	Radiation:	North	East	South	West	Horizontal	
Weather 1: <input type="text" value="-6,8"/> °C		<input type="text" value="11"/>	<input type="text" value="29"/>	<input type="text" value="88"/>	<input type="text" value="32"/>	<input type="text" value="41"/>	W/m ²
Weather 2: <input type="text" value="-5,9"/> °C		<input type="text" value="8"/>	<input type="text" value="9"/>	<input type="text" value="39"/>	<input type="text" value="29"/>	<input type="text" value="23"/>	W/m ²
Ground design temp. <input type="text" value="13,6"/> °C							

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Factor always 1 (except "X")	TempDiff 1 K	TempDiff 2 K	PT 1 W	PT 2 W
External wall - Ambient	A	1269,4	0,145	1,00	26,8	25,9	4917	4752
External wall - Ground	B	122,6	0,151	1,00	6,4	6,4	118	118
Roof/Ceiling - Ambient	A	1590,7	0,118	1,00	26,8	25,9	5046	4876
Floor slab / Basement ceiling	B	1585,5	0,148	1,00	6,4	6,4	1500	1500
	A			1,00	26,8	25,9		
	X			0,00	26,8	25,9		
Windows	A	262,6	0,863	1,00	26,8	25,9	6077	5873
Exterior door	A	37,0	0,900	1,00	26,8	25,9	893	863
Exterior TB (length/m)	A	167,0	0,050	1,00	26,8	25,9	224	216
Perimeter TB (length/m)	P	211,9	0,150	1,00	6,4	6,4	203	203
Ground TB (length/m)	B	239,6	0,150	1,00	6,4	6,4	229	229
Building element towards neighbour	I			1,00	3,0	3,0		
Total							19207	18631

Transmission heat load P_T

Ventilation system:	A _{TFA} m ²	Clear room height m	Effective air volume, V _V m ³	Heat recovery efficiency of the heat exchanger η _{HR}	Heat recovery efficiency SHX	Heat recovery efficiency SHX	Heat recovery efficiency SHX	Heat recovery efficiency SHX
	<input type="text" value="2043,1"/>	<input type="text" value="6,33"/>	<input type="text" value="12935"/>	<input type="text" value="92%"/>	<input type="text" value="0%"/>	<input type="text" value="0%"/>	<input type="text" value="0%"/>	<input type="text" value="0%"/>
Energetically effective air changes n _v	n _{V,Res} (Heating Load) 1/h	n _{V,system} 1/h	Φ _{HR}	Φ _{HR}	1/h	1/h		
	<input type="text" value="0,105"/>	<input type="text" value="0,464"/>	<input type="text" value="0,92"/>	<input type="text" value="0,92"/>	<input type="text" value="0,143"/>	<input type="text" value="0,143"/>		

Ventilation heat load P_V

V _V m ³	n _v 1/h	n _v 1/h	c _{air} Wh/(m ³ K)	TempDiff 1 K	TempDiff 2 K	P _V 1 W	P _V 2 W
12935,4	0,143	0,143	0,33	26,8	25,9	16387	15836

Total heating load P_L

P _T + P _V	PL 1 W	PL 2 W
<input type="text" value="35594"/>	<input type="text" value="35594"/>	<input type="text" value="34468"/>

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _T 1 W	P _T 2 W
North	5,0	0,5	0,53	12	14	18	20
East	182,0	0,5	0,52	15	4	747	189
South	0,0	0,0	0,40	88	39	0	0
West	75,6	0,5	0,13	56	37	300	197
Horizontal	0,0	0,0	0,40	41	23	0	0
Total						1065	405

Solar heating power P_S

Spec. power W/m ²	A _{TFA} m ²	P _I 1 W	P _I 2 W
<input type="text" value="1,6"/>	<input type="text" value="2043"/>	<input type="text" value="3269"/>	<input type="text" value="3269"/>

Internal heating load P_I

P _T + P _I	P _G 1 W	P _G 2 W
<input type="text" value="4334"/>	<input type="text" value="4334"/>	<input type="text" value="3674"/>

Heating power (gains) P_G

P _L - P _G	<input type="text" value="31261"/>	<input type="text" value="30793"/>
---------------------------------	------------------------------------	------------------------------------

Heating load P_H

Area specific space heating load P_H / A_{TFA}

Input max. supply air temperature	<input type="text" value="52"/> °C	Supply air temperature without heating	<input type="text" value="17,8"/> °C
Max. supply air temperature θ _{Supply,Max}	<input type="text" value="52"/> °C	Supply air temperature without heating	<input type="text" value="17,9"/> °C

For comparison: heating load transportable by the supply Air P_{Supply Air,Max}

P _{Supply Air,Max}	<input type="text" value="67735"/> W specific:	<input type="text" value="33,2"/> W/m ²
Supply air heating: Sufficient?	<input type="text" value="Yes"/>	


Cooling: energy value for useful cooling energy

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Interior Temperature: **25** °C
 Building type: **Športna dvorana**
 Treated Floor Area A_{TFA}: **2043** m²

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year	
Heating degree hours - Exterior	19,1	16,0	14,4	11,0	7,2	4,4	3,8	3,7	7,4	10,6	14,3	18,6	130	kKh
Heating degree hours - Ground	8,3	7,7	8,5	8,0	8,0	6,2	6,1	6,0	7,0	7,4	7,4	8,0	88	kKh
Losses - Exterior	41451	34499	30953	23555	14934	8843	7516	7304	15655	22731	30944	40420	278806	kWh
Losses - Ground	2406	2213	2445	2314	2302	1794	1771	1727	2015	2136	2153	2323	25598	kWh
Losses summer ventilation	7671	6372	5699	4323	2711	1580	1422	1321	2862	4190	5724	7486	51359	kWh
Sum spec. heat losses	25,2	21,1	19,1	14,8	9,8	6,0	5,2	5,1	10,0	14,2	19,0	24,6	174,1	kWh/m ²
Solar load North	16	28	48	70	89	93	93	80	53	37	19	13	640	kWh
Solar load East	769	1271	2492	3196	4494	4606	5002	3983	2657	1403	674	513	31059	kWh
Solar load South	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar load West	1038	1255	1808	2177	2416	2406	2584	2542	2055	1510	943	714	21446	kWh
Solar load Horiz.	0	0	0	0	0	0	0	0	0	0	0	0	0	kWh
Solar load Opaque	233	339	586	750	963	994	1064	911	648	409	222	164	7284	kWh
Internal heat gains	3192	2883	3192	3089	3192	3089	3192	3192	3089	3192	3089	3192	37584	kWh
Sum spec. loads solar + internal	2,6	2,8	4,0	4,5	5,5	5,5	5,8	5,2	4,2	3,2	2,4	2,2	48,0	kWh/m ²
Utilisation factor losses	10%	13%	21%	31%	56%	88%	86%	94%	41%	23%	13%	9%	27%	
Useful cooling energy demand	0	0	0	0	5	481	2774	1002	0	0	0	0	4261	kWh
Spec. cooling demand	0,0	0,0	0,0	0,0	0,0	0,2	1,4	0,5	0,0	0,0	0,0	0,0	2,1	kWh/m ²
Specif. dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,6	1,0	0,0	0,0	0,0	0,0	1,6	kWh/m ²
Sensible fraction	100%	100%	100%	100%	100%	100%	69%	32%	100%	100%	100%	100%	56%	



Summer ventilation

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Building volume:	12935	m ³	Building type:	Športna dvorana
Max. indoor absolute humidity:	12	g/kg	Heat recovery efficiency:	92%
Internal humidity sources:	100	g/(P*h)	Humidity recovery efficiency:	0%
			Subsoil heat exchanger efficiency:	0%

Results passive cooling		Results active cooling		
Frequency of overheating:	10,8%	at the overheating limit $\theta_{max} = 25$ °C	Useful cooling demand:	2,1 kWh/(m ² a)
max. humidity:	14,9	g/kg	Dehumidification demand:	1,6 kWh/(m ² a)
Frequency of exceeded humidity:	13,4%		Frequency of exceeded humidity:	0,0%

Summer basic ventilation to ensure adequate air quality

Air change rate via vent. system with supply a:	0,32	1/h	HRV/ERV in summer (check only one field)		
			None <input type="checkbox"/>		
			Automatic bypass, controlled by temperature difference <input checked="" type="checkbox"/>		
			Automatic bypass, controlled by enthalpy difference <input type="checkbox"/>		
			Always <input type="checkbox"/>		
Air change rate via extract air system:		1/h	Specific power consumption (for extract air system):		Wh/m ³
Window ventilation air change rate:		1/h			

Effective air change rate

	$n_{V,system}$ 1/h	η_{SHX}	η_{HP}	$n_{V,equi.fraction}$ 1/h
Exterior $n_{V,e}$	0,320	0%	0,92	0,026
without HR	0,320	0%		0,320
Ground $n_{L,g}$	0,320	0%	0,92	0,000
without HR	0,320	0%		0,000

Ventilation conductance

	V_V m ³	$n_{V,equi.fraction}$ 1/h	C_{Air} Wh/(m ³ K)		
exterior $H_{V,e}$	12935	0,026	0,33	=	112,6 W/K
without HR	12935	0,320	0,33	=	1366,0 W/K
ground $H_{V,g}$	12935	0,000	0,33	=	0,0 W/K
without HR	12935	0,000	0,33	=	0,0 W/K
Infiltration, window, extract air system	12935	0,042	0,33	=	179,3 W/K

Additional summer ventilation for cooling

Additional ventilation regulation

Minimum acceptable indoor temp. 22,0 °C

Type of additional ventilation

Window night ventilation, manual	Night ventilation value:		1/h
Mechanical, automatically Controlled ventilation	Corresponding air change rate during operation, in addition to basic air change	0,10	1/h
	Specific power consumption	0,21	Wh/m ³
	Controlled by (please check)	Temperature diff.	<input checked="" type="checkbox"/>
		Humidity diff.	<input type="checkbox"/>

Compressor - cooling units

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Building type:	Športna dvorana		Treated floor area A _{TFA} :	2043,1	m ²
Interior temperature summer:	25,0	°C	Mechanical cooling:	x	
Nominal humidity:	12,0	g/kg	Air change rate via ventilation system with supply air:	0,3	
Internal humidity sources:	7,3	g/(m ³ h)			

Supply air cooling

check as appropriate

On/Off mode (check as appropriate)		
Max. cooling capacity (sensible + latent)	70,0	kW
Temperature reduction dry	49,7	K
Seasonal energy efficiency ratio	3,0	

Recirculation cooling

check as appropriate

On/Off mode (check as appropriate)	x	
Max. cooling capacity (sensible + latent)	30,0	kW
Volume flow rate at nominal power	10000	m ³ /h
Temperature reduction dry	8,8	K
Variable air volume (check if appropriate)		
Seasonal energy efficiency ratio	2,97	

Additional dehumidification

check as appropriate

Waste heat to room (check if appropriate)	x
Seasonal energy efficiency ratio	3,0

Panel cooling

check as appropriate

Seasonal energy efficiency ratio	
----------------------------------	--

	Sensible kWh/(m ² a)	Latent kWh/(m ² a)	COP	Electricity demand (kWh/a) kWh/(m ² a)	Sensible fraction
Useful cooling total	2,1	1,6			56%
Cooling contribution by:					
Supply air cooling	(2,1 + 0,1) /	3,0	=	0,7	97%
Recirculation cooling	(0,0 + 0,0) /	3,0	=	0,0	0%
Dehumidification		1,6	/	2,2	0%
Remaining for panel cooling			/	0,0	100%
Cooling distribution	0,6		/	3,0	100%
Total	(2,7 + 1,6) /	2,6	=	1,6	62%
Unsatisfied demand	0,0	0,0			
				Cooling demand covered?	Yes

(Yes/No)

Cooling load

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Building type: Športna dvorana

Treated floor area A_{TFA}: 2043,1 m² Spec. capacity: 204 Wh/(m²h)
 Building volume: 12935 m³ Nominal humidity: 12,0 g/kg
 Interior temperature: 25 °C Internal humidity sources: 7,3 g/(m²h)

Temperature: Outdoor air Dew point Sky
 Weather 1: 25,9 °C 17,6 °C 15,2 °C
 Weather 2: 25,9 °C 17,6 °C 17,6 °C
 Ground design temp. 17,0 °C SHX 11,8 °C
 Radiation: North East South West Horizontal
 47 114 131 124 203 W/m²
 47 114 131 124 203 W/m²

Building assembly	Temperature zone	Area m ²	U-Value W/(m ² K)	Factor always 1 (except "X")	TempDiff 1 K	TempDiff 2 K	P _T 1 W	P _T 2 W
External wall - Ambient	A	1269,4	0,145	1,00	0,9	0,9	165	165
External wall - Ground	B	122,6	0,151	1,00	-8,0	-8,0	-148	-148
Roof/Ceiling - Ambient	A	1590,7	0,118	1,00	0,9	0,9	169	169
Floor slab / Basement ceiling	B	1585,5	0,148	1,00	-8,0	-8,0	-1884	-1884
	A			1,00	0,9	0,9		
	A			1,00	0,9	0,9		
	X			0,00	0,9	0,9		
Windows	A	262,6	0,863	1,00	0,9	0,9	204	204
Exterior door	A	37,0	0,900	1,00	0,9	0,9	30	30
Exterior TB (length/m)	A	167,0	0,050	1,00	0,9	0,9	8	8
Perimeter TB (length/m)	P	211,9	0,150	1,00	-8,0	-8,0	-255	-255
Ground TB (length/m)	B	239,6	0,150	1,00	-8,0	-8,0	-288	-288
Building element towards neighbour	I			1,00	3,0	3,0		
Radiation correction outdoor air			L _{ambiant} W/K		-47,5	0,9	-43	-43
Radiation correction sky			L _{Sky} W/K		46,6	-9,8	-455	-345

Transmission heat load P_T Total = -2497 or -2387

V _V m ³	n _{V,equl} fraction 1/h	n _{V,equl} fraction 1/h	C _{Air} Wh/(m ³ K)	TempDiff 1 K	TempDiff 2 K	P _V 1 W	P _V 2 W
Exterior P _{V,o}	12935	0,068	0,33	0,9	0,9	263	263
Ground P _{V,e}	12935	0,000	0,33	-13,2	-13,2	0	0
Summer ventilation P _{V,S}	12935	0,043	0,33	-2,6	-2,6	-477	-477

Ventilation heat load P_V Total = -214 or -214

Orientation of the area	Area m ²	g-Value (perp. radiation)	Reduction factor (see 'Windows' worksheet)	Radiation 1 W/m ²	Radiation 2 W/m ²	P _S 1 W	P _S 2 W
North	5,0	0,5	0,61	63	63	104	104
East	182,0	0,5	0,60	86	86	5121	5121
South	0,0	0,0	0,40	131	131	0	0
West	75,6	0,5	0,64	137	137	3568	3568
Horizontal	0,0	0,0	0,40	203	203	0	0
Sum opaque areas						1254	1254

Solar load P_S Total = 10048 or 10048

Spec. power W/m ²	A _{TFA} m ²	P _I 1 W	P _I 2 W
2,1	2043	4290	4290

Internal heating load P_I

P_T + P_V + P_S + P_I = 11627 or 11737

Cooling load P_C = 11737 W

Area specific cooling load P_C / A_{TFA} = 5,7 W/m²

Please enter the minimum supply air temperature. 18 °C Supply air temperature without cooling 25,1 °C

For comparison: cooling load, transportable through the supply air P_{Supply;Max} = 9663 W

specific: 4,7 W/m²

Air conditioning over the supply air possible? No

Daily internal temperature stroke
 ((-2387,3 + (-214,2) + 10047,6) * 24 / (204)) = 0,4 K

Absolute humidity exterior air	Absolute humid. supply air	Humid. load, supply air	Humidity load, internal
12,6 g/kg	12,6 g/kg	2969 g/h	15000 g/h
641 kg/h	4884 kg/h	2969 g/h	15000 g/h
674 kg/h	4884 kg/h	2969 g/h	15000 g/h
800 g/h	15000 g/h	2969 g/h	15000 g/h

Enthalpy of vaporisation 707,639 Wh/kg / 1000 g/kg * Humidity load 18769 g/h = 13281 W

Dehumidification load P_T = 13281 W

Area specific dehumidification load P_T / A_{TFA} = 6,5 W/m²

Monthly average values	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Specific cooling demand	0,0	0,0	0,0	0,0	0,0	0,2	1,4	0,5	0,0	0,0	0,0	0,0
Specific dehumidification demand	0,0	0,0	0,0	0,0	0,0	0,0	0,6	1,0	0,0	0,0	0,0	0,0
Sensible fraction	100%	100%	100%	100%	100%	100%	69%	32%	100%	100%	100%	100%

Minimum of sensible cooling load fraction occurred = 32%

Primary Energy Renewable PER

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Building type:	Športna dvorana
Treated floor area A _{TFA} :	2043 m ²
Projected building footprint A _{Projected} :	1588 m ²
Heating demand incl. distribution & hydr. frost protection:	25 kWh/(m ² a)
Cooling energy dem. incl. dehumidification:	4 kWh/(m ² a)
DHW demand including distribution:	13 kWh/(m ² a)

Selection of heat generation system(s)

Primary heat generation type

3-District heating, CGS

Secondary heat generation type (optional & different)

2-Heat pump(s)

Contribution margin (useful energy)	
Heating	DHW
100%	65%
0%	35%

Addl. input in following worksheets

District heat
HP, possibly HP ground


Energy demand Reference: Treated floor area	Efficiency		Final energy		PER			PE		CO ₂	
	Calculati on	User defined value	Contribution (final energy)	Final energy demand	PER factor	Effective PER factor (including biomass)	PER specific value	PE factor	PE value	CO ₂ emissions factor (CO ₂ -eq)	CO ₂ -eq emissions
	-	-		kWh/(m ² a)	kWh/kWh	kWh/kWh	kWh/(m ² a)	kWh/kWh	kWh/(m ² a)	kg/kWh	kg/(m ² a)
								8-PE factors user determined		2-CO2 factors user determined	
							57,2	39,9	8,5		
Heating			100%			1,05	32,3	0,35	10,8		2,3
Electricity (HP compact unit)					1,85			2,50		0,530	
Electricity (heat pump)					1,85			2,50		0,530	
District heating: 21-Gas CHP (small) 35% CHP	0,95		100%	26,5	0,85 1,43 1	0,92	24,3	0,00	0,0	0,000	0,0
Wood and other biomass					1,10			-		-	
Natural gas / RE gas					1,75			1,10		0,200	
Heating oil / RE methanol					2,30			1,10		0,280	
Solar thermal system											
Electricity (direct)					1,85			2,50		0,530	
Other											
Aux. electricity (heating, wintertime ventilation)				4,3	1,85	1,85	8,0	2,50	10,8	0,530	2,3
Cooling and dehumidification						1,20	5,1		10,7		2,3
Electricity cooling (heat pump)	2,97			0,9	1,15			2,50	2,3	0,530	0,5
Auxiliary electricity cooling, ventilation summer				2,5	1,15			2,9	6,4	0,530	1,4
Electricity dehumidification (heat pump)	2,21			0,7	1,40			1,0	1,8	0,530	0,4
Auxiliary electricity (dehumidification)				0,1	1,40			2,50	0,2	0,530	0,0
DHW generation			100%			1,16	13,7	0,58	6,8		1,4
Electricity (HP compact unit)					1,30			2,50		0,530	
Electricity (heat pump)	1,90		35%	2,5	1,30	1,30	3,2	2,50	6,2	0,530	1,3
District heating: 21-Gas CHP (small) 35% CHP	0,95		65%	9,1	0,85 1,43 1	1,11	10,2	0,00	0,0	0,000	0,0
Wood and other biomass					1,10			-		-	
Natural gas / RE gas					1,75			1,10		0,200	
Heating oil / Methanol					2,30			1,10		0,280	
Solar thermal system											
Electricity (direct)					1,30			2,50		0,530	
Other											
Aux. electricity (DHW + solar DHW)				0,3	1,30	1,30	0,4	2,50	0,7	0,530	0,1
Household electricity				4,7		1,30	6,0		11,6		2,5
Electricity (household or non-residential lighting, etc.)				4,7	1,30	1,30	6,0	2,50	11,6	0,530	2,5
Auxiliary electricity (other)					1,30			2,50		0,530	
Gas / RE gas dry/cook				0,0	1,75		0,0	2,50	0,0	0,215	0,0

Energy generation Reference: Projected building footprint area	Final energy		PER		PE		CO ₂	
	Final energy generation	Final energy generation	PER factor	PER specific value	PE factor	PE Value	Emission factor (CO ₂ -eq)	CO ₂ -eq emissions
	kWh/a	kWh/(m ² a)	kWh/kWh	kWh/(m ² a)	kWh/kWh	kWh/(m ² a)	kg/kWh	kg/a
				0,0		0,0		0,0
PV electricity	0	0,0	1,00	0,0	-	0,0	-	0,0
Solar thermal system	0	0,0	-	0,0	1,20	0,0	-	0,0
User determined energy carrier	0	0,0	1,00	0,0	2,50	0,0	0,530	0,0

PE demand requirement in case of verification through PE (non-renewable) [kWh/(m ² a)]	-	Current building reaches following class	40	Requirement met?	-
---	---	--	----	------------------	---

Achievable energy standard through the verification of renewable primary energy (assessment of individual aspects)	Useful energy, performance				Airtightness
	Annual heat dem. Treated floor area kWh/(m ² a)	Heating load Treated floor area W/m ²	Useful cool. energy Treated floor area kWh/(m ² a)	Cooling load Treated floor area W/m ²	
Requirement Passive House Premium					1/h
Requirement Passive House Plus	15	10	17	10	0,60
Requirement Passive House Classic					
Requirement PHI Low Energy Building	30		32		1,00
Current building reaches following class for aspect	24	15	4	6	0,6
	PHI Low Energy Building				Premium

Summary	Final energy		PER		PE value		CO ₂ eq emissions		CO ₂ eq substitution balance
	MWh/a	MWh/a	8-PE factors user determined	2-CO2 factors user determined	MWh/a	kg/a	kg/a		
Though, from the scientific point of view, not entirely correct, different energy carriers will be added together here. This is done to meet the criteria of other energy standards.									
Demand	105,5	116,8	81,57	17292	57,80	12254	12254		
Generation	0,0	0,0	0,00	0	57,80	12254	12254		
Demand, cumulative generation (annual balance)	105,49	116,76	81,57	17292	57,80	12254	12254		
Demand w/o household electricity	96,0	104,4							
Demand w/o household electricity, cum. generation	95,98	104,41							



Heat pump

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

		Building type:	Športna dvorana	
	Treated floor area A_{TFA} :		2043	m ²
Covered fraction of space heating demand	(<i>PER</i> worksheet)		0%	
Space heating demand + distribution losses	$Q_{H1}+Q_{HL}$ (<i>DHW+Distribution</i>)		51466	kWh/a
Solar fraction for space heat	$\eta_{Solar, H}$ (<i>SolarDHW</i> worksheet)		0%	
Effective annual heating demand	$Q_{H,WI}=Q_H*(1-\eta_{Solar, H})$		0	kWh/a
Covered fraction of DHW demand	(<i>PER</i> worksheet)		35%	
Total heating demand of DHW system	Q_{gDHW} (<i>DHW+Distribution</i>)		28050	kWh/a
Solar fraction for DHW	$\eta_{Solar, DHW}$ (<i>SolarDHW</i> worksheet)		0%	
Effective DHW demand	$Q_{DHW,WI}=Q_{DHW}*(1-\eta_{Solar, DHW})$		9817	kWh/a
Number of heat pumps in the system			1	
Functionality			DHW	
Heating				
Selection of HP:	1-Toplotna črpalka zrak/voda	Heat source:	1-Outdoor air	
Selection of distribution system			3-Supply air heating	
Design distribution temperature	θ_{design} (<i>DHW+Distribution</i>)		55,00	°C
Nominal power of distribution system	P_{nom}		70,00	kW
Distribution system (to be completed by experienced users only)				
Nominal power of distribution system	P_{nom}		70,00	kW
Radiator exponent	n			
Heat storage tank (buffer storage tank 'DHW+Distribution' worksheet)			0-No	
Specific heat losses storage	$U * A_{Storage}$			W/K
Storage location in thermal envelope			1-Inside	
Room temperature (storage location: outside of thermal envelope)	(<i>DHW+Distribution</i>)			°C
Sink temperature of heat pump for heating	θ_{snk}		55,00	°C
Entries in relation to the domestic hot water system				
Selection of HP:	1-Toplotna črpalka zrak/voda	Heat source:	1-Outdoor air	
DHW temperature	(<i>DHW+Distribution</i>)		60,00	°C
Orientation of DHW storage tank ('storage 1' in 'DHW+Distribution' worksheet)			1-Inside	
Specific heat losses storage	$U * A_{Storage}$		3,0	W/K
Room temperature (storage location: outside of thermal envelope)	(<i>DHW+Distribution</i>)		20,00	°C
Type of backup heater			1-Elec. Immersion heater	
$\Delta\theta$ of electric continuous flow water heater				K
Additional options in case of one heat pump for both functions: Heating & DHW				
Same heat pump's sink temperature for Heating and for DHW			1-Yes	
Heat pump priority	(<i>Manufacturer, tech. data</i>)		2-Heating priority	
Control strategy				
Heat pump control strategy			2-Ideal	
Heating				
Depth ground water / Ground collector / Ground probe	z			m
Power of pump for ground heat exchanger	P_{pump}			kW

District heating and combined heat power (CHP)

Energy balance calculation with PHPP Version 9.6a

Šolski center Slovenj Gradec - telovadnica / Climate: Ljubljana T1996-2005/J1981-2000 / TFA: 2043 m² / Heating: 24,5 kWh/(m²a) / Cooling: 3,7 kWh/(m²a) / PER: 57,2 kWh/(m²a)

Building type:	Športna dvorana	
Treated floor area A _{TFA} :	2043	m ²
Covered fraction of space heating demand	(PER worksheet)	100%
Annual heating demand kWh/a	Q _H (DHW+Distribution)	51466 kWh
Solar contribution for space heating	η _{Solar, H} (SolarDHW worksheet)	0%
Effective annual heating demand	Q _{H,WI} = Q _H * (1 - η _{Solar, H})	51466 kWh
Covered fraction of DHW demand	(PER worksheet)	65%
DHW demand	Q _{DHW} (DHW+Distribution)	27314 kWh
Solar contribution for DHW	η _{Solar, DHW} (SolarDHW worksheet)	0%
Effective DHW demand	Q _{DHW,WI} = Q _{DHW} * (1 - η _{Solar, DHW})	17754 kWh

Definition of heat source for PE factor and CO ₂ emissions	21-Gas CHP (small) 35% CHP	kWh _{PE} /kWh _{Final}	kg/kWh
Definition of heat source for calculation of PER factor		0,00	0,000
Heat net	Efficiency district heating net		
	95%		

CHP complex & boiler for peak loads	Fraction	Efficiency Electricity	Heat	PER factors	PER factors
CHP complex	90%	30%	65%	1,10	0,85
Boiler for peak loads	10%		96%	1,85	1,43
Total	100%			1,30	1,00

Performance ratio of heat transfer station	η _{a,HX}	105%	
Utilisation factor of heat transfer station	η _{a,SHX}	95%	

Final energy demand heat generation	Q _{Final} = Q _{Use} * η _{a,DH}	72863 kWh/a	35,7 kWh/(m ² a)
Annual PE demand (non-renewable primary energy)		0 kg/a	0,0 kg/(m ² a)
Annual CO ₂ -equivalent emissions		0 kg/a	0,0 kg/(m ² a)